NARODOWY INSTYTUT ZDROWIA PUBLICZNEGO PZH
– Państwowy Instytut Badawczy
National Institute of Public Health NIH – National Research Institute

HYGIENIC CERTIFICATE

B.BK.60110.1790.2026

ORYGINAŁ

Product: Deck-mounted, wall-mounted, freestanding and concealed mixer taps, series: B, V, X
Containing: brass CW 617N, brass CW510L, stainless steel, ceramics, ABS, NBR, PEX
Hygienically suitable for: installation in systems conveying water intended for human consumption and domestic hot water
Hygiene-related comments and recommendations: After installation and after a longer break in use, the taps must be flushed with a strong stream of water.The hygienic certificate does not cover the assessment of the technical parameters, functional properties or allergenic potential of the product.

Producer: Deante Sp. z o.o.
ul. Twarda 11/13
95-100 Zgierz

Applicant: Deante Sp. z o.o.
ul. Twarda 11/13
95-100 Zgierz

Date of issue: 25 sierpnia 2026
Expiry date: 9 lipca 2029

Maciej Szczotko, PhD
Head of the
Department of Environmental Health and Safety
NIPH NIH – NRI

This document becomes invalid if the product formulation or manufacturing process changes; scientific evidence indicates health risks from its use; applicable legislation changes; or the label text or instructions for use are amended without agreement with NIZP PZH – PIB. It is valid only in conjunction with the corresponding entry in the online register at: www.rejestr-atestow.pzh.gov.pl.

Contact regarding this hygienic certificate: Department of Environmental Health and Safety NIPH NIH – NRI, 00-791 Warsaw, Chocimska 24, Poland
e-mail: sekretariat-bk@pzh.gov.pl tel. +48 22 54-21-354, +48 22 54-21-349